SCALE:

	Pavement Section				Right-of-Way Widths (feet)					Cul-De-Sacs (feet)	
Classification	Riding Surface ①	Base	Aggregate Base (see note 1)	Sub Base 4	(C) Total Width	(A) Back of Curb to Back of Curb (minimum)	(B) Back of Curb to Front of Sidewalk (minimum)	Sidewalk Width	Behind Sidewalk (max.)	ROW Radius	Back of Curb Radius
Residential ADT < 401	2" SM 12.5A	N/A	6" NO. 21 or 21A	N/A	50	25	5	5	2' 6"	60	50
Residential ADT > 401	2" SM 12.5A	N/A	6" NO. 21 or 21A	N/A	50	31	3' 6"	5	1	60	50
Collector	2" 12.5D	4" BM 25.0	6" NO. 21 or 21A	N/A	60	31	3' 6"	5	6	60	50
Industrial	2" IM19.0A	5" BM 25.1	6" Cement Treated Stabilized Aggregate Base	4" No. 21 or 21A	50	31	3' 6"	5	1	70	60

## NOTES:

- 1. FOR ALL STREET CLASSIFICATIONS: AGGREGATE BASE SHALL BE SEALED WITH LIQUID BITUMINOUS MATERIAL CRS-2 AT THE RATE OF 0.3 GALLONS PER SQUARE YARD AND COVERED WITH No. 78 STONE AT THE RATE OF 15 POUNDS PER SQUARE YARD. THIS IS NOT REQUIRED IF BASE ASPHALT OF 4" OR GREATER IS INSTALLED.
- 2. THE DESIGN DEPTHS SHOWN ABOVE ARE MINIMUM REQUIREMENTS. ACTUAL DEPTHS SHALL BE DETERMINED THROUGH CBR TESTING AND ANALYSIS.